

Nr. crt.	Tip incap.	Denumire incapere	S (mp)	Qnec (W)	Tip radiator	Nr. radiator	TEMP INCAP.	Qinst (W)
<b>DEMISOL</b>								
1	D-01	Atelier electric	33.37	5672.90	4x22(600x700)	R1,R2,R3,R4	18	6120
2	D-02	Grup sanitar	4.630	593.80	1x11(600x600)	R5	20	700
3	D-03	Atelier mecanic	38.290	4441.64	4x22(600x500)	R6,R7,R8,R9	18	4372
Total incalzire demisol				10708.34				11192
<b>PARTER</b>								
1	P01	W.C.	2.16	238.14	1x11(600x400)	R1	20	466
2	P02	W.C.	2.500	275.63	1x11(600x400)	R2	20	466
3	P03	Vestiar medici	18.140	2222.15	2x22(600x500)	R3,R4	22	2186
4	P04	Hol	8.550	837.90	1x22(600x400)	R5	18	874
5	P05	Hol	6.510	637.98	1x11(600x600)	R6	18	700
6	P06	Club vestiar	22.890	2804.03	1x22(600x1300)	R7	22	2841
7	P07	Amfiteatru	76.090	17120.25	4x22(600x2000)	R8,R9,R10,R11	20	17480
8	P08	GS studenti	7.26	996.44	1x22(600x500)	R12	20	1093
9	P09	Magazie	8.630	789.65	1x22(600x400)	R13	12	874
10	P10	Casa scarilor	11.760	1434.72	1x22(600x700)	R14	18	1530
11	P11	Wind-fang	4.870	594.14	1x11(600x600)	R15	18	700
12	P12	Atelier electric	33.830	5751.10	2x22(600x1300)	R16,R17	18	5682
13	P13	Grup sanitar	5.290	714.15	1x11(600x600)	R18	20	700
14	P14	Camera de garda	9.280	1392.00	1x22(600x600)	R19	22	1311
15	P15	Camera de garda	14.980	2247.00	1x22(600x1000)	R20	22	2185
16	P16	Spatiu Pol. front.	8.840	1193.40	1x22(600x500)	R21,R22	20	1093
17	P17	Hol	5.930	800.55	1x22(600x400)	R23	20	874
Total incalzire parter				40049.21				41055
<b>ETAJ I</b>								
18	E1-01	W.C.	1.84	211.14	1x11(600x400)	R1	20	466
19	E1-02	W.C.	1.610	184.75	1x11(600x400)	R2	20	466
20	E1-03	Vestiar medici	13.260	1690.65	2x22(600x400)	R3,R4	22	1748
21	E1-04	Hol	6.100	622.20	1x11(600x400)	R5	18	700
22	E1-05	Vestiar medici	10.900	1389.75	1x22(600x700)	R6	22	1530
23	E1-06	Sala consultatie ORL	18.650	2377.88	2x22(600x500)	R7,R8	22	2186
24	E1-07	Amfiteatru	76.090	17120.25	4x22(600x2000)	R9,R10,R11,R12	20	17480
25	E1-08	Grup sanitar	8.77	1183.95	1x22(600x500)	R13	22	1093
26	E1-09	Statistica	6.960	845.64	1x22(600x400)	R14	20	874
27	E1-10	Statistica	7.900	959.85	1x22(600x500)	R15	20	1093
28	E1-11	Casa scaril	9.650	1042.20	1x22(600x500)	R16	18	1093
29	E1-12	Depozit-arhiva	33.850	4112.78	2x22(600x1000)	R17,R18	20	4370
30	E1-13	Spatiu Pol. front.	4.400	534.60	1x11(600x600)	R19	20	700
Total incalzire etaj 1				32275.63				33799

ETAJ II								
31	E2-01	W.C.	1.84	269.10	1x11(600x400)	R1	20	466
32	E2-02	W.C.	1.610	235.46	1x11(600x400)	R2	20	466
33	E2-03	Vestiar medici	13.260	2154.75	2x22(600x500)	R3,R4	22	2186
34	E2-04	Hol	6.100	793.00	1x22(600x400)	R5	18	874
35	E2-05	Camera de garda	10.900	1771.25	1x22(600x800)	R7	22	1748
36	E2-06	Salon	18.650	3030.63	2x22(600x700)	R8,R9	22	3060
37	E2-07	Salon	19.300	3136.25	1x22(600x1400)	R10,R11	22	3059
38	E2-08	Salon	10.16	1651.00	1x22(600x800)	R12	22	1748
39	E2-09	Salon pediatrie	13.240	2151.50	1x22(600x1000)	R13	22	2185
40	E2-10	Salon pediatrie	13.920	2262.00	1x22(600x1000)	R14	22	2185
41	E2-11	Hol	15.580	2025.40	2x22(600x500)	R15,R16	18	2186
42	E2-12	W.C.	3.480	508.95	1x11(600x600)	R17	20	700
43	E2-13	W.C.	3.480	508.95	1x11(600x600)	R18	20	700
44	E2-14	Hol+casa scarilor	17.690	2299.70	1x22(600x1100)	R19	18	2404
45	E2-15	Camera tratamente	17.340	2817.75	1x22(600x1300)	R20	22	2841
46	E2-16	Oficiu hrana	10.610	1379.30	1x22(600x1300)	R21	18	2841
47	E2-17	Spatiu Pol. front.	45.280	6622.20	3x22(600x1000)	R22,R23,R24	20	6555
Total incalzire etaj 2				33617.19				36204
ETAJ III								
48	E3-01	W.C.	1.84	227.70	1x11(600x400)	R1	20	466
49	E3-02	W.C.	1.610	199.24	1x11(600x400)	R2	20	466
50	E3-03	Vestiar medici	13.260	1823.25	2x22(600x400)	R3,R4	22	1748
51	E3-04	Hol	6.100	671.00	1x11(600x600)	R5	18	700
52	E3-05	Vestiar medici	11.620	1597.75	1x22(600x800)	R7	22	1748
53	E3-06	Salon	17.930	2465.38	2x22(600x600)	R8,R9	22	2622
54	E3-07	Salon	36.730	5050.38	1x22(600x1200)	R10,R11	22	5244
55	E3-08	Salon	13.38	1839.75	1x22(600x900)	R12	22	1967
56	E3-09	Salon	13.780	1894.75	1x22(600x900)	R13	22	1967
57	E3-10	Hol	13.920	1531.20	2x22(600x400)	R14,R15	18	1748
58	E3-11	W.C.	3.480	430.65	1x11(600x600)	R16	20	700
59	E3-12	W.C.	3.480	430.65	1x11(600x600)	R17	20	700
60	E3-13	Casa scarii	11.520	1267.20	1x22(600x600)	R18	18	1311
61	E3-14	Hol	6.170	678.70	1x11(600x600)	R19	18	700
62	E3-15	Oficiu tratamente	16.730	2718.63	1x22(600x1300)	R20	22	2841
63	E3-16	Oficiu hrana	10.020	1302.60	1x22(600x600)	R21	18	1311
Total incalzire etaj 3				24128.81				26239
ETAJ IV								
64	E4-01	Casa scarii	8.52	749.76	1x22(600x400)	R1	18	874
65	E4-02	Sala rezervoare	36.130	2980.73	2x22(600x700)	R2,R3	12	3060
Total incalzire etaj 4				3730.49				3934
TOTAL INCALZIRE				144509.66				152423